

CERTIFICATE OF COMPLIANCE

Certificate Number 20180312-E466310
Report Reference E466310-20140726
Issue Date 2018-MARCH-12

Issued to: REAL TIME AUTOMATION INC
N26 W23315 Paul Rd
Pewaukee WI 53072

**This is to certify that
representative samples of**

INFORMATION TECHNOLOGY EQUIPMENT FOR USE IN
HAZARDOUS LOCATIONS

USL, CNL - Component - Process Control Equipment for
use in Class I, Division 2, Groups A, B, C and D Hazardous
Locations.

Protocol Gateway xxxxxxxxxx-N34; where "xxxxxxx" may be any alpha numeric character or blank.

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety:


Standard No. ANSI/ISA 12.12.01, 2015, Nonincendive
Electrical Equipment for Use in Class I and II, Division 2
and Class III, Divisions 1 and 2 Hazardous (Classified)
Locations,
Standard No. CAN/CSA C22.2 No. 213-15, 1st Ed., Non-
incendive Electrical Equipment for Use in Class I, Division 2
Hazardous Locations.

Additional Information:

See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

